

This document is an extension of reports P224269 - DEC/2 and P233422 - DEC/2

CLASSIFICATION REPORT

Established according to the article 5 of the Department State Order dated 21 November 2002

VALIDITY 5 YEARS from 4 August 2022

N° P224269 - DEC/2

Material submitted by: IGEPA BELUX
Nijverheidslaan 4
9880 Aalter
Belgium
Ongrofoam free foamed PVC sheet

Commercial trademark: Ongrofoam foamed PVC sheet
B Foam

Brief description:
Global composition : Not fireproof material composed of PVC
End-use: Advertising, construction
Mass per unit area: 961 to 4100 g/m²
Thickness 2 to 10 mm
Colour: Diverse

Test report: N° P224269 - DEC/2 dated 4 August 2022 and P233442 – DEC/2 dated 3 August 2023

Type of tests: Determination of classification according to NF P 92-507 (February 2004)
Radiation test according to NF P 92-501 (December 1995)

Classification:

M1

VALID FOR ANY APPLICATION FOR WHICH THE PRODUCT IS NOT SUBJECT TO CE MARKING

Durability of classification (NF P 92-512 : 1986): A PRIORI UNLIMITED

In view of criteria resulting from the tests described in the appended Test Report N° P224269 - DEC/2 and P233442 – DEC/2

To determine the classification, uncertainty on the results has not been taken into account.

The indicated classification prejudices in no way the conformity of the materials commercialized to the samples submitted to the tests and can in no way be considered as a certificate of qualification. This is not a product certification according to the L115-27 article of the consumption code and to the law dated on 3rd June 1994.

Is allowed only the integral reproduction of either this classification report consisting of this unique page, or the whole classification report.

Trappes, August 29, 2023



**The Head of Energy, Environment and
Combustion Division**

Thibaut Cornillon

Traduction du Document P224269 - DEC/1 et P233442 – DEC/1 réalisée par le LNE. La version en langue française fait foi

522 R 0900-02 Rév.G